



Embassy of the United States of America

Tokyo, Japan

June 30, 2022

First Set of Questions and Answers

Request for Quotations (RFQ) No. 19JA8022Q0027
Bathroom Restoration Services for U.S. Embassy Tokyo, Japan

Question 1:

"We have a question regarding the renovation of the bathroom on the 4th floor of the Chancery.
We checked the stock of the LIXIL toilet wall tile MLA-200/1N specified by the Embassy with the manufacturer.
They replied that it has been discontinued and is no longer in stock. As this tile design is common throughout the new bathroom of the Chancery, we have looked for an equivalent design but have not found one.
According to the manufacturer, there is no successor model.

Please advise what we should do.

Answer 1:

The Contractor shall furnish ECP-303/NTC1, or its equivalent approved by COR. See Amendment No. A001.

-End of First Set of Questions and Answers-