



Embassy of the United States of America

Tokyo, Japan

August 3, 2022

First Set of Questions-and-Answers (Qs&As)

Request for Quotations No. 19JA80-22-Q-0036
Multi-Type Heat Pump Unit Replacement Services

Question 1:

"Is an anti-harmonic active filter for outdoor units NOT needed to provide?
?"

Answer 1:

No, anti-harmonic active filter for outdoor units is not required.

-End of First Set of Qs&As-